



University of Tehran

High Voltage Laboratory

Test Report

No: 96H062

**50 kVA Distribution Transformer
Iran Transfo Rey Co.**





Test Report No 96H062

Test Object:	50kVA distribution transformer
Type:	TSUN4744L
Serial Number:	362866
Manufacturer:	Iran Transfo Rey Co. (Islamic Republic of Iran)
Test Performed on order of:	Iran Transfo Rey Co. (Islamic Republic of Iran)
Test Scope:	Short-time withstand current test
Tests Procedure:	According to standard IEC 60076: Power transformers Part 5: Ability to withstand short circuit
Test Performed:	December 26, 2017
Test Result:	Indicated in Report <u>The test result refers to the tested object only.</u>



Short-time withstand current test on 50kVA distribution transformer- S/N:362865
Iran Transfo Rey Co. production



High Voltage Laboratory
University of Tehran
14395-515, Tehran, Iran
Tel.: +98 21 88011247, Fax: +98 21 88027766

Page 3/12

High Current Laboratory Participants:

Test assistants:

M. H. Samimi

H. Dadashi

Test Leader

S. Mohseni

Head of Laboratory:

A. A. Shayegani Akmal



Tehran, 23 April 2018

Short-time withstand current test on 50kVA distribution transformer- S/N:G62865
Iran Transfo Rey Co. production



High Voltage Laboratory

University of Tehran

14395-515, Tehran, Iran

Tel.: +98 21 88011247, Fax: +98 21 88027766

Page 4/12

Contents

	Pages
1. Description of test object	5
2. Scope of test agreed upon	5
3. Short-time withstand current test	5

This Report contains, 12 numbered pages

4 photos

1 drawing

15 oscillograms



Short-time withstand current test on 50kVA distribution transformer- S/N:362865
Iran Transfo Rey Co. production



1. Description of test object

The test object was 50kVA distribution transformer, manufactured by Iran Transfo Rey Co. (Iran).



2. Scope of tests agreed upon

The accepted testing method was conforming to international standard "IEC 60076: Power Transformers-Part 5: Ability to withstand short circuit"

3. Short-time withstand current test

This arrangement was composed of a high current transformer, time controlled switch and a proper capacitor bank. The scheme is shown on Figure 1. The transformer under test has been supplied with 1810 A current for 0.5 S and the current has been measured.




Figure 1: Scheme of short-time withstand current test

The total number of tests was nine; three tests in each tap position. Current waveforms are shown in figures 2 to 10.

Short-time withstand current test on 50kVA distribution transformer
Iran Transfo Rey Co. production






Figure 2: Current waveform, Tap1, No.1




Figure 3: Current waveform, Tap1, No. 2




Figure 4: Current waveform, Tap1, No. 3

Short-time withstand current test on 50kVA distribution transformer
Iran Transfo Rey Co. production






Figure 5: Current waveform, Tap2, No. 1




Figure 6: Current waveform, Tap2, No. 2




Figure 7: Current waveform, Tap2, No. 3

Short-time withstand current test on 50kVA distribution transformer-
Iran Transfo Rey Co. production






Figure 8: Current waveform, Tap3, No. 1




Figure 9: Current waveform, Tap3, No. 2




Figure 10: Current waveform, Tap3, No. 3


Short-time withstand current test on 50kVA distribution transformer- S. Iran Transfo Rey Co. production






3.1. Frequency Response Analysis (FRA) comparison before and after high current tests

Red: before HC test , Blue: After HC test



Short-time withstand current test on 50kVA distribution transformer S/N 30-2865
Iran Transfo Rey Co. production






Transfer function type	Tap under test	Reference terminal	Measurement terminal	Comparison result	Tap under test
End-to-End	Tap 1	V	W	Intact	Tap 1



Transfer function type	Tap under test	Reference terminal	Measurement terminal	Comparison result	Tap under test
Capacitive Inter-winding	Tap 1	U	u	Intact	Tap 1



Short-time withstand current test on 50kVA distribution transformer- S/N:562316
Iran Transfo Rey Co. production



Short-time withstand current test on 50kVA distribution transformer- S/N:52 High Voltage Laboratory
Iran Transfo Rey Co. production





3.2. Visually inspection the core and windings by removing the active part from the tank after short circuit tests



Figure 18: One side of the transformer active part for inspection



Figure 19: The other side of the transformer active part for inspection

Result: Test Passed Successfully.

Short-time Withstand current test on 500 kVA distribution transformer S/N 362867
Pao Transfo Ray Co. production

